

Pavement Testing Services Ltd
 Unit 7, Cowling Business Park
 Canal Side, CHORLEY, PR6 0QL
 T: 01257 233 242
 F: 01257 234 744
 E: info@ptsinternational.co.uk



4076

TEST REPORT

Determination of Liquid and Plastic Limits

BS1377: Part 2: 1990

Client: Gallaghers
 Site: James Corbett Road, Salford
 Location: Stockpile
 Date Sampled: 18/11/2011

Report No: 1119-G-01-A-105
 Date received: 28/11/2011
 Date tested: 02/12/2011
 Date reported: 15/12/2011

Sample Ref.	Lab ref.	Sample Description	Sample Type	Sample Prep.	% Ret. 425µm sieve	Moisture Content %	Liquid Limit %	Plastic Limit %	Plasticity Index %
Gal18/11/2011	Lab/11/4921	Type 1 subbase + SMR	B	W	79.0	6.2	NP	NP	NP

Legend: **D** = Disturbed, **B** = Bulk, **U** = Undisturbed
N = tested in natural condition, **A** = air dried before test, **W** = subject to wet sieving before test
NP = Non-plastic

Comments: Interpretations and opinions expressed herein are outside the scope of the UKAS Accreditation
 Certified that the test was carried out in accordance with BS 1377: Part 2: 1990: Methods 3.0, 4.4 & 5
 PASS

Signed: _____
 Mike Hayes (Laboratory Manager)
 D.Foster (Assistant Laboratory Manager)
 J.Hopkinson (Senior Technician)